| MY WATER SMELLS LIKE SOLVENTS OR PAINT THINNER | | | | | | | | |
|---|--|--|---|---|---|-----------------|---|--|
| POSSIBLE PROBLEM | HEALTH CONCERN? | OTHER CLUES & CONSIDERATIONS | CONFIRM IT | POSSIBLE FIXES | LICENSE REQUIRED FOR FIX? | STATE FUNDS? | MORE INFO | |
| Iron Bacteria See <u>Iron</u> <u>Bacteria</u> brochure | No, iron bacteria live off iron in the water. They are a nuisance, but not a threat to your health. There is no drinking water | Is there evidence of iron in your water; for example, red stains on plumbing fixtures or on laundry? Has there been a period of little or no water use? Does the problem fluctuate with water use? | Request a lab test for iron bacteria. <u>Laboratorie</u> <u>s certified</u> <u>to test for</u> <u>coliform</u> <u>bacteria</u> | Flush system and use more water Periodic shock chlorination | No No, but licensed <u>Well</u> <u>Drillers</u> or <u>Pump</u> <u>Installers</u> have the knowledge and equipment. | No | <u>Iron in</u> <u>Drinking</u> <u>Water</u> brochure <u>UWSP-Well</u> <u>Water Quality</u> <u>Viewer</u> | |
| | standard for iron bacteria. | | may also test for iron bacteria. Ask the lab. | Well cleaning | No, but licensed <u>Well</u> <u>Drillers</u> or <u>Pump</u> <u>Installers</u> have the knowledge and equipment. | No | <u>Center for</u> <u>Watershed</u> <u>Science and</u> <u>Education,</u> | |
| | | | | Continuous pellet chlorination | Licensed <u>Pump Installers</u> or well owners must install. DNR recommends that license holders install. | No | <u>UW-Stevens</u> <u>Point</u> <u>United States</u> <u>Geological</u> <u>Survey</u> <u>National</u> <u>Ground</u> <u>Water</u> <u>Association</u> <u>Water</u> <u>Systems</u> | |
| | | | | | | | <u>Council</u> <u>National</u> <u>Sanitation</u> <u>Foundation</u> | |

| MY WATER SMELLS LIKE SOLVENTS OR PAINT THINNER, CONTINUED | | | | | | | | |
|---|--|--|--|---|---|--|--|--|
| POSSIBLE PROBLEM | HEALTH CONCERN? | OTHER CLUES & CONSIDERATIONS | CONFIRM IT | POSSIBLE FIXES | LICENSE REQUIRED FOR FIX? | STATE FUNDS? | MORE INFO | |
| Volatile Organic Compounds or VOCs See <u>VOC's in</u> Drinking <u>Water</u> brochure. | Yes, if the contaminants exceed <u>drinking water</u> <u>standards</u> . | Is there a manufacturing facility or dry cleaning operation nearby? Does the problem stay constant even with fluctuations in water use? | Send a sample to a <u>laboratory</u> <u>certified by</u> <u>DNR to test</u> <u>for VOCs</u> . For the least cost, test for diesel range organics (DRO) or gasoline range organics (GRO) or the Safe Drinking Water VOC test. A full screen for VOCs is expensive. | Install a Dept. of Safety and Professional Services <u>approved</u> <u>water</u> <u>treatment</u> <u>device</u> - from the search dropdown, select products; then from the type of product dropdown, choose plumbing products and from the select product description dropdown, choose water treatment device. Deepen well casing or drill new well | Yes, treatment devices must be installed by <i>licensed</i> <i>plumbers</i> ; or in some cases may be installed by the owner/occupant of a single family private residence. See <i>plumbing</i> <i>license laws</i> . Be sure the device chosen is capable of removing the level of contaminant you have In your water. Yes, licensed <u>Well</u> <i>Drillers</i> . | Yes, if drinking water standards are exceeded; eligibility criteria are met, and approval received first. See well replacement program. | United States Geological SurveyNational Ground Water AssociationWater Systems CouncilNational Sanitation FoundationCenter for Watershed Science and Education, UW- Stevens Point | |

| MY WATER SMELLS LIKE SOLVENTS OR PAINT THINNER, CONTINUED | | | | | | | | |
|---|--|---|---|---|---|-----------------|--|--|
| POSSIBLE PROBLEM | HEALTH CONCERN? | OTHER CLUES AND CONSIDERATIONS | CONFIRM IT | POSSIBLE FIXES | LICENSE REQUIRED FOR FIX? | STATE FUNDS? | MORE INFO | |
| Sulfates | Possibly. It can act as a laxative. See the Department of Health Services <u>Fact Sheet on</u> <u>Sulfates</u> . | Does the water have an astringent odor? Sulfates make the water acidic and more likely to cause corrosion of metal pipes. | Send a sample to a <u>laboratory</u> <u>certified by</u> <u>DNR to</u> <u>perform</u> <u>sulfate</u> <u>analyses</u> . | Install a Dept. of Safety and Professional Services <u>approved</u> <u>water</u> <u>treatment</u> <u>device</u> - from the search dropdown, select products; then from the type of product dropdown, choose plumbing products and from the select product description dropdown, choose water treatment device. | Yes, treatment devices must be installed by licensed plumbers; or in some cases may be installed by the owner/occupant of a single family private residence. See <i>plumbing license laws</i> . Be sure the treatment device chosen is capable of removing the level of contaminant you have in your water. | No | United States Geological Survey National Ground Water Association Water Systems Council National Sanitation Foundation Foundation Center for Watershed Science and Education, UW- Stevens Point | |