MY WATER STAINS LAUNDRY BLACK OR BROWN							
LIKELY	HEALTH	OTHER CLUES &	CONFIRM	POSSIBLE	LICENSE REQUIRED	STATE	MORE
PROBLEM	CONCERN?	CONSIDERATIONS	IT	FIXES	FOR FIX?	FUNDS?	INFO
Manganese	Possibly, if	Do you have black	Test your	Install a Dept.	Yes, treatment devices	No	UWSP Well
or	levels are	specks in your	water for	of Safety and	must be installed by		<u>Water</u>
Manganese	very high.	water? When you	manganese	Professional	<u>licensed plumbers</u> ; or in		<u>Quality</u>
and Iron	Manganese	rub the specks	and iron.	Services	some cases may be		<u>Viewer</u>
See	is a	between your fingers,	Contact a	approved water	_		
<u>Iron in</u>	necessary	does it leave a black	<u>laboratory</u>	<u>treatment</u>	owner/occupant of a		<u>United</u>
<u>Drinking</u>	mineral for	powder? Do you	certified by	<u>device</u> - from the	single family private		<u>States</u>
<u>Water</u>	good health	have dark stains on	DNR to test	search dropdown, select products;	residence. See		<u>Geological</u>
brochure.	and there is	plumbing fixtures?	<u>for</u>	then from the type	plumbing license laws.		<u>Survey</u>
	not a primary		<u>manganese</u>	of product			A. C. C.
	drinking		and iron.	dropdown, choose	Be sure the treatment		<u>National</u>
	water			plumbing products and from the	device chosen is capable		<u>Ground</u>
	standard for			select product	of removing the amount		<u>Water</u> Association
	manganese. There is			description	of manganese and iron		<u>ASSOCIATION</u>
	however, a			dropdown, choose	you have in your water.		Water
	nuisance			water treatment device.			<u>Systems</u>
	standard for			device.			Council
	manganese.			Devices are			<u>Oddricii</u>
	Also, EPA			listed under			National
	has issued a			contaminants			Sanitation
	health			they will			Foundation
	advisory for			remove.			
	manganese.						Center for
	See the						Watershed
	Department						Science and
	of Health						Education,
	Services						<u>UW-Stevens</u>
	Fact Sheet						<u>Point</u>
	<u>on</u>						
	<u>Manganese</u> .						